



## Standard Installation & Compliance Requirements for all Installation Instructions

### INSTALLATION & COMPLIANCE REQUIREMENTS

Installation of this system must be carried out by a licensed plumber in accordance with the Plumbing Code of Australia (PCA), AS/NZS 3500 (all relevant parts), and any applicable state or local regulations.

Failure to comply with these requirements will void the manufacturer's warranty and may constitute a breach of any applicable insurance policies.

For correct operation, the installer and end user must follow all manufacturer instructions provided with this system and on their website.

Do not use this system with water that is microbiologically unsafe or of unknown quality without adequate disinfection before the system.

Do not modify, alter, or substitute any components unless using equivalent WaterMark certified components.

Do not dismantle or separate the system except where required as part of the installation procedure outlined by the manufacturer.

### INSTALLATION AND SERVICING ASSISTANCE

For any assistance related to the installation and servicing of this system, please contact **1300 808 966** or send an email to: [info@purewatersystems.com.au](mailto:info@purewatersystems.com.au)

### ADDITIONAL REQUIREMENTS - APPLY WHERE RELEVANT TO EACH SYSTEM INSTALLATION GUIDE

#### **Backflow, Pressure & Protection - all systems**

Where required OR supplied, appropriate backflow prevention devices, pressure limiting valves, and isolation valves must be installed in accordance with AS/NZS 3500, and any applicable state or local regulations.

#### **Drainage Requirements - Reverse Osmosis, Whole House, Chillers and Softeners**

Any drain connection must be installed in accordance with AS/NZS 3500.2 and incorporate an approved air gap where required.

#### **System Integrity - all systems**

To ensure correct operation, the system must be installed as supplied and must not be altered or reconfigured outside manufacturer guidelines.

#### **Location & Environmental Protection - all systems**

The system must be installed in a location that is accessible for servicing and protected from damage, weather, and temperature extremes. Do not install in direct sunlight.

Do not install outdoors unless the system and components are specifically designed for external installation.

#### **Water Quality - all systems**

Systems designed for cyst reduction may be used on disinfected water that may contain filterable cysts.

Use of reverse osmosis systems may increase bacterial content if not properly maintained or without supplementary disinfection.

For more information contact:

**Pure Water Systems (Aust.) Pty Ltd**

27 Leda Drive | PO Box 685, Burleigh Heads QLD 4220

☎ 1300 808 966 | ✉ [info@purewatersystems.com.au](mailto:info@purewatersystems.com.au) | 🌐 [purewatersystems.com.au](http://purewatersystems.com.au)